

FINISHED GRADE
OR SUBGRADE

BACKFILL MATERIAL
CONSISTING OF
CRUSHED ROCK,
SUITABLE EXCAVATED
MATERIAL OR BANK RUN
GRAVEL AS REQUIRED,
OR DIRECTED BY CITY

DETECTABLE TRACER
TAPE AND PIPE
IDENTIFICATION

SPECIAL PRECAUTIONS
TO PROTECT PIPE TO
THIS LEVEL

HAND-PLACED,
COMPACTED SUITABLE
NATIVE OR IMPORTED
FILL

RIGID STORM DRAIN
PIPE AS SPECIFIED
PER CITY STANDARDS

FOUNDATION GRAVEL
AS REQUIRED

UNDISTURBED EARTH

DEPTH VARIES

3' MINIMUM

1'-0"

1/2

*

SEE PIPE
BELOW O.D.

VARIES

CITY OF CASTLE ROCK

RIGID STORM DRAIN PIPE
TRENCH SECTION

APPROVED:

DWG. NO.

BY CITY

DATE

CR001SW

DATE:

2/06

DRWN:

P.E.

CHKD:

M.B.J.

SCALE:

NONE

* 4-INCHES FOR PIPE 18-INCH DIA. AND
LESS 6-INCHES FOR PIPE GREATER
THAN 18-INCH DIA.