



MINIMUM SIDEWALK WIDTHS
 5' MINIMUM, 10' MAXIMUM
 SEE DESIGN STANDARDS

- NOTES:
1. THRU JOINTS AND CONTRACTION JOINTS SHALL BE AS SHOWN ABOVE. THRU JOINTS SHALL ALSO BE PLACED IN THE SIDEWALK SECTION AT DRIVEWAY AND ALLEY RETURNS. ALL JOINTS SHALL BE CLEAN AND EDGED WITH AN EDGE HAVING 1/4" RADIUS. JOINTS SHALL BE FLUSH WITH THE FINISHED SURFACE.
 2. ALL UTILITY POLES, METER BOXES, ETC. IN SIDEWALK AREAS SHALL HAVE 3/8" JOINT MATERIAL (FULL DEPTH) PLACED AROUND THEM BEFORE PLACING CONCRETE.
 3. PREMOLDED JOINT FILLER SHALL BE 3/8" x 2" ASPHALT. MASTIC MATERIAL.
 4. FORMS SHALL BE EITHER WOOD OR STEEL AND SHALL MEET ALL REQUIREMENTS OF THESE SPECIFICATIONS.
 5. CONCRETE SHALL BE CLASS 3000 PSI.
 6. WHERE ROLLED CURBS ARE ALLOWED, SIDEWALKS SHALL BE MIN. 6" THICK.

SIDEWALK WITHOUT PLANTING STRIP

CITY OF CASTLE ROCK			
SIDEWALK WITHOUT PLANTING STRIP			
APPROVED:		DWG. NO.	
_____		CRO12ST	
BY CITY		DATE	
DATE:	DRWN:	CHKD:	SCALE:
2/06	J.H.	T.J.O.	NONE